

DECLARATION OF CONFORMITY

We, **Cooper Fulleon Ltd,
Llantarnam Park,
Cwmbran, South Wales,
United Kingdom.
NP44 3AW**

declare under our sole responsibility that the product(s)

RoLP LX Wall Base

(Fire Alarm Device – Sounders for Fire Detection & Fire Alarm Systems)

Manufactured at the following site,

**Cooper Fulleon Ltd, Llantarnam Park, Cwmbran, South Wales, United Kingdom.
NP44 3AW**

is (are) in conformity with the following standard(s) or other normative document(s)

EN 61000-6-3:2007 + A1: 2011, EN 50130-4:2011 (EMC)

EN 54-3:2001 + A1:2002 + A2:2006, BS IEC 60092-504:2001, BS IEC 60533:1999 (MED)

when used in the following applications & conditions:

Fire detection & Alarm Systems (Type A)

following the provisions of the directive(s):

2004/108/EC EMC

96/98/EC MED

24th February 2016

Date of Declaration



**Ian Stokes, Technical Director
Cooper Fulleon Limited**

Year of affixing the CE-marking: 2011